

## SUMMARY REPORT

**Applicant :** INCONTROL TECH SDN. BHD.  
 No.15, Jalan BRP 9/1D,  
 Perusahaan Bukit Rahman Putra,  
 47000 Sungai Boluh,  
 Selangor Darul Ehsan, Malaysia.

**Product :** Product : REMOTE TERMINAL UNIT (RTU)  
 Brand : Brodersen  
 Model : MP32e, PS24A, SP04  
 LB2 DI20A/B/C, DI12H, DO12R, DO08R, DO20A  
 AI08A, AO02A

The **BRODERSEN** RTU ( Brand : **MP32E** ) has been tested according to the following standards for EMC requirements.


MEASUREMENT ITEM	Severity level	Result
Emissions Test :		
Radiated emission : CISPR 22 : 2005	CISPR 22 Class A	Pass
Immunity Test :		
IEC 61000-4-2 : 2001	Class IV	Criteria A
IEC 61000-4-3 : 2006	Class III	Criteria A
IEC 61000-4-4 : 2006	Class III	Criteria A
IEC 61000-4-5 : 2005	Class IV	Criteria A
IEC 61000-4-6 : 2006	Class III	Criteria A
IEC 61000-4-8 : 2001	Class IV	Criteria A
IEC 61000-4-12 : 2006	Class III	Criteria A
IEC 61000-4-16 : 2002	Class IV	Criteria A
IEC 61000-4-29 : 2000	Class IV	Criteria A
IEC 60255-5 : 2000	Dielectric - 2.5 kV	Criteria A
	Impulse - 5.0 kV	Criteria A

Prepared by

*(Signature)*  
 MAHSOL MAHYUDDIN  
 Technical Executive  
 EMC Testing Section  
 Tel : 03-55446153  
 Email : mahsol@sirim.my  
 Date : 23<sup>rd</sup> October 2017

SIRIM QAS INTERNATIONAL SDN. BHD.  
 (Company No. 410334-X)

Building 4, SIRIM Complex  
 1, Persiaran Dato' Menteri  
 Section 2, P.O. Box 7035  
 40911 Shah Alam  
 Selangor Darul Ehsan  
 MALAYSIA.



ISO/IEC 17025  
 SAMM 085  
 SAMM 086  
 SAMM 087  
 SAMM 219  
 SAMM 231  
 SAMM 299

Tel : 60-3-5544 6400  
 Fax : 60-3-5510 9439  
<http://www.sirim-qas.com.my>